

Location of Tactile and Braille Signs

Disability (Access to Premises – Buildings) Standards 2010

Schedule Part D4

Signs including symbols, numbering and lettering must be designed and installed as follows:

- (a) *Braille and Tactile components of a sign must be located not less than 1200mm and not higher than 1600mm above the floor or ground surface.*
- (b) *Signs with single lines of characters must have the line of tactile characters not less than 1250mm and not higher than 1350mm above the floor or ground surface.*
- (c) *Signs identifying rooms containing features or facilities listed in D3.6 must be located –*
 - (i) *on the wall on the latch side of the door with the leading edge of the sign located between 50mm and 300mm from the architrave; and*
 - (ii) *where (i) is not possible, the sign may be placed on the door itself.*

